Location: HORIZON RESOURCES FAIRVIEW STORE

605 S Ellery Ave Fairview, MT 59221 Richland

Facility Code: 27175 Last Inspected On: 05/20/2020 System Facility ID:42-03363 Operating Permit Renewal Date: 07/24/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Horizon Resources 7015722172

Operator Contact: Darcie Yadon;Ronald Rolle 7015722172

Owner/Operator: Horizon Resources

Darcie Yadon, UST Class A Operator Darcie Yadon, UST Class B Operator Ronald Rolle, UST Class A Operator Ronald Rolle, UST Class B Operator

Tank Code	07	Tank Age	24	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3722	Spill Test Date	12/14/2021	Piping Installed Date	01/24/2011	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/09/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7800	ATG Test Date	12/14/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	12/14/2021			ATG Type	Veeder Root/8484 Series PLLD;Veeder Root/TLS-450				
Tank Code	08	Tank Age	24	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3723	Spill Test Date	12/14/2021	Piping Installed Date	01/24/2011	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/09/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4200	ATG Test Date	12/14/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

Page [1] of [26] Report Created: 11/1/2022

		Overfill Test Date	12/14/2021			ATG Type	Veeder Root/8484 Series PLLD;Veeder Root/TLS-450				
Tank Code	09	Tank Age	24	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3724	Spill Test Date	12/14/2021	Piping Installed Date	01/24/2011	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/09/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5500	ATG Test Date	12/14/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	12/14/2021			ATG Type	Veeder Root/8484 Series PLLD;Veeder Root/TLS-450				
Tank Code	10	Tank Age	24	Tank Installed Date	12/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3725	Spill Test Date	12/14/2021	Piping Installed Date	01/24/2011	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/09/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4500	ATG Test Date	12/14/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	12/14/2021			ATG Type	Veeder Root/8484 Series PLLD;Veeder Root/TLS-450				
Tank Code	15	Tank Age	11	Tank Installed Date	01/02/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5274	Spill Test Date	12/14/2021	Piping Installed Date	01/24/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/14/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

Report Created: 11/1/2022 Page [2] of [26]

		Overfill Test Date	12/14/2021			ATG Type	Gilbarco-Veeder Root/TLS- 450;Veeder Root/8484 Series PLLD;Veeder Root/TLS-450				
Tank Code	16	Tank Age	11	Tank Installed Date	01/02/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5275	Spill Test Date	12/14/2021	Piping Installed Date	01/24/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/14/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	12/14/2021			ATG Type	Gilbarco-Veeder Root/TLS- 450;Veeder Root/8484 Series PLLD;Veeder Root/TLS-450				

Location: LOAF 'N JUG #714

516 S Ellery Ave

Fairview, MT 59221 Richland

Facility Code: 27193 Last Inspected On: 07/20/2022

System Facility ID:42-03914 Operating Permit Renewal Date: 10/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mini Mart Inc dba Loaf 'N Jug Pueblo 5139641568

Operator Contact: Theodore Bezel;Mini Mart Inc dba Loaf 'N Jug Pueblo 5139641568

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

Theodore Bezel, UST Class A Operator Theodore Bezel, UST Class B Global Operator Theodore Bezel, UST Class B Operator

Tank Code	06	Tank Age	9	Tank Installed Date	03/01/2013		Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5410	Spill Test Date	10/22/2020	Piping Installed Date	03/01/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Report Created: 11/1/2022 Page [3] of [26]

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/28/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	07/20/2022	Line Tightness Test Date	07/20/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.1	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/22/2020			ATG Type	Gilbarco-Veeder Root/TLS- 350;Gilbarco- Veeder Root/TLS- 350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	07	Tank Age	9	Tank Installed Date	03/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5411	Spill Test Date	10/22/2020	Piping Installed Date	03/01/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/28/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/20/2022	Line Tightness Test Date	07/20/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.1	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/22/2020			ATG Type	Gilbarco-Veeder Root/TLS- 350;Gilbarco- Veeder Root/TLS- 350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	08	Tank Age	9	Tank Installed Date	03/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5412	Spill Test Date	10/22/2020	Piping Installed Date	03/01/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	[Sump Tightness Test Date	08/28/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/20/2022	Line Tightness Test Date	07/20/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.1	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

Report Created: 11/1/2022 Page [4] of [26]

Overfill Test Date 10/22/2020 ATG Type Gilbarco-Veeder Root/TLS350;GilbarcoVeeder Root/TLS350/Gilbarco EMC;Veeder Root/8484 Series PLLD

Facility Summary in Richland County in the City of Lambert

Location: NORTANA GRAIN CO 100 1st Ave SW

Lambert, MT 59243 Richland

System Facility ID:42-00317

Facility Code: 27067
Last Inspected On: 10/26/2021
Operating Permit Renewal Date: 03/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Nortana Grain Co;Shane Keller 4064432580;4064784122

Operator Contact: Mike Arneson; Shane Keller 4064784122; 4064893589

Owner/Operator: Nortana Grain Co

Owner/Operator: Shane Keller

Mike Arneson, UST Class A Operator Mike Arneson, UST Class B Operator Shane Keller, UST Class A Operator Shane Keller, UST Class B Operator

Tank Code	S5	Tank Age	13	Tank Installed Date	03/06/2009	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5201	Spill Test Date		Piping Installed Date	10/20/2008	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	06/09/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	21000	ATG Test Date		Line Tightness Test Date	06/09/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S6	Tank Age	13	Tank Installed Date	03/06/2009	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5202	Spill Test Date		Piping Installed Date	10/20/2008	Tank Construction		Piping Construction	Double Walled	AST	Yes

Report Created: 11/1/2022 Page [5] of [26]

Tank Status	Currently in Use	MLLD Test Date	03/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	21000	ATG Test Date		Line Tightness Test Date	06/09/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	13	Tank Installed Date	03/06/2009	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5203	Spill Test Date		Piping Installed Date	10/20/2008	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	03/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	13000	ATG Test Date		Line Tightness Test Date	06/09/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S8	Tank Age	13	Tank Installed Date	03/06/2009	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5204	Spill Test Date		Piping Installed Date	10/20/2008	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	03/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	06/09/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S9	Tank Age	13	Tank Installed Date	03/06/2009	Tank Material	Concrete	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5205	Spill Test Date		Piping Installed Date	10/20/2008	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	03/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	21000	ATG Test Date		Line Tightness Test Date	06/09/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date			T	ATG Type					T

Report Created: 11/1/2022 Page [6] of [26]

Location: VALLEY FUEL SUPPLY

MT Hwy 16 Savage, MT 59262 Richland

System Facility ID:42-03815

Facility Code: 27187 Last Inspected On: 03/04/2021 Operating Permit Renewal Date: 03/14/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Gregory Cross

Operator Contact: Gregory Cross;R J Serpe;Timothy Fife

Owner/Operator: Greg Cross

Greg Cross, UST Class A Operator R J Serpe, UST Class A Operator R J Serpe, UST Class B Global Operator Ron Serpe, UST Class B Global Operator Timothy Fife, UST Class A Operator

Tank Code	03	Tank Age	24	Tank Installed Date	08/25/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	780	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date	11/18/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/09/2022	Line Tightness Test Date	12/01/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	04	Tank Age	24	Tank Installed Date	08/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	781	Spill Test Date	09/02/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date	11/18/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/09/2022	Line Tightness Test Date	11/13/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

Page [7] of [26] Report Created: 11/1/2022

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	05	Tank Age	24	Tank Installed Date	08/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	782	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date	11/18/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3000	ATG Test Date	08/09/2022	Line Tightness Test Date	08/09/2011	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Location: LOAF 'N JUG #712

706 S Central Ave

Sidney, MT 59270-4939 Richland

Facility Code: 27233 Last Inspected On: 07/20/2022

Operating Permit Renewal Date: 10/04/2025 System Facility ID:42-05084

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Mini Mart Inc dba Loaf 'N Jug Pueblo 5139641568

Operator Contact: John Sumowski;Randal Liebnow;Theodore Bezel;Mini Mart Inc 5139641568

dba Loaf 'N Jug Pueblo

Owner/Operator: Mini Mart Inc dba Loaf 'N Jug Pueblo

Carl Watkins, UST Class B Operator

Eileen Campbell, UST Class B Operator

Hiede Richardson, UST Class B Global Operator

John Sumowski, UST Class A Operator

Randal Liebnow, UST Class A Operator

Randal Liebnow, UST Class B Global Operator

Richie Lesser, UST Class B Operator

Scott Huether, UST Class B Global Operator

Stevie Ulstad, UST Class B Operator

Page [8] of [26] Report Created: 11/1/2022

Theodore Bezel, UST Class A Operator
Theodore Bezel, UST Class B Global Operator
Theodore Bezel, UST Class B Operator
Timothy Osterman, UST Class B Operator
Toni Mullen, UST Class B Global Operator

Tank Code	01	Tank Age	46	Tank Installed Date	04/24/1976	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4586	Spill Test Date	10/21/2020	Piping Installed Date	12/22/2010	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/28/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	10/21/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/20/2022	Line Tightness Test Date	07/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/21/2020			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	02	Tank Age	46	Tank Installed Date	04/24/1976	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4587	Spill Test Date	10/21/2020	Piping Installed Date	12/22/2010	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/28/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	10/21/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/20/2022	Line Tightness Test Date	07/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/21/2020			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
Tank Code	03	Tank Age	46	Tank Installed Date	04/24/1976	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4588	Spill Test Date	10/21/2020	Piping Installed Date	12/22/2010	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/28/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/20/2022	Tank/Piping CP Test Date	10/21/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Report Created: 11/1/2022 Page [9] of [26]

Capacity	4000	ATG Test Date	07/20/2022	Line Tightness Test Date	07/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	10/21/2020			- JI -	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				

Report Created: 11/1/2022 Page [10] of [26]

Location: LOWER YELLOWSTONE RURAL ELECTRIC ASSOCIATION

INC

3200 W Holly St Sidney, MT 59270 Richland

System Facility ID:42-00001

Facility Code: 27062 Last Inspected On: 04/14/2021 Operating Permit Renewal Date: 09/29/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lower Yellowstone Rural Electric Association Inc 4064821602

Operator Contact: Bodrey Kindopp; Justin King 4064881602

Owner/Operator: Lower Yellowstone Rural Electric Association Inc

Bodrey Kindopp, UST Class A Operator Justin King, UST Class A Operator Justin King, UST Class B Global Operator Mike Eberling, UST Class B Global Operator

Tank Code	05	Tank Age	29	Tank Installed Date	10/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1558	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	06	Tank Age	29	Tank Installed Date	10/01/1993	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1559	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Richland County in the City of Sidney

Page [11] of [26] Report Created: 11/1/2022

Location: METZ FUEL and SERVICE

625 S Central Ave

Sidney, MT 59270-4936 Richland

System Facility ID:42-03224

Facility Code: 27172
Last Inspected On: 09/25/2021
Operating Permit Renewal Date: 09/29/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Metz Fuel Service Inc

Operator Contact: Jim Metz 4064801872

Owner/Operator: Metz Fuel Service Inc

Jim Metz, UST Class A Operator
Jim Metz, UST Class B Global Operator

Tank Code	10	Tank Age	31	Tank Installed Date	07/11/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2110	Spill Test Date	12/15/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/25/2021			ATG Type					
Tank Code	11	Tank Age	31	Tank Installed Date	07/11/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2111	Spill Test Date	12/15/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/25/2021			ATG Type					
Tank Code	12	Tank Age	31	Tank Installed Date	07/11/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2112	Spill Test Date	12/15/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Report Created: 11/1/2022 Page [12] of [26]

Tank Status	Currently in Use	MLLD Test Date	03/11/2022	Sump Tightness Test Date	08/27/2016	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mecha nical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	03/11/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/25/2021			ATG Type	Veeder Root/Red Jacket FXID				
Tank Code	13	Tank Age	31	Tank Installed Date	07/11/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2113	Spill Test Date	12/15/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/11/2022	Sump Tightness Test Date	08/27/2016	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring;Mecha nical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	03/11/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/15/2021			ATG Type	Veeder Root/Red Jacket FXIV				

Location: MILLERS CORNER

2201 W Holly St Sidney, MT 59270 Richland

Facility Code: 30723 Last Inspected On: 11/19/2019 Operating Permit Renewal Date: 04/14/2023

System Facility ID:56-14071

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Millers Corner LLC 4064334041

Operator Contact: Gregory Miller; Nitin Patel 4064334041

Owner/Operator: Millers Corner LLC

Gregory Miller, UST Class A Operator Gregory Miller, UST Class B Global Operator

Nitin Patel, UST Class A Operator Nitin Patel, UST Class B Operator

Page [13] of [26] Report Created: 11/1/2022

Tank Code	01	Tank Age	19	Tank Installed Date	02/06/2003	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4797	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/20/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	11/20/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Franklin Fueling Systems/TS- LLD;Incon/TS-550				
Tank Code	02	Tank Age	19	Tank Installed Date	02/06/2003	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4798	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/20/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	11/20/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Franklin Fueling Systems/TS- LLD;Incon/TS-550				
Tank Code	03	Tank Age	19	Tank Installed Date	02/06/2003	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4799	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/20/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	11/20/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Franklin Fueling Systems/TS- LLD;Incon/TS-550				
Tank Code	04	Tank Age	10	Tank Installed Date	08/01/2012	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5387	Spill Test Date	08/30/2021	Piping Installed Date	08/16/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Report Created: 11/1/2022 Page [14] of [26]

Tank Status	Currently in Use	MLLD Test Date	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	Tank/Piping CP Test Date	11/20/2019	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	Line Tightness Test Date	11/20/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date			ATG Type	Franklin Fueling Systems/TS- LLD;Incon/TS-550				

Location: SIDNEY AIRPORT SERVICE

355 Airport Rd

Sidney, MT 59270-0355 Richland

Facility Code: 27214 Last Inspected On: 12/14/2021

System Facility ID:42-04444 Operating Permit Renewal Date: 02/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sidney Airport Service

Operator Contact:

Owner/Operator: Sidney Airport Service

Tank Code	03	Tank Age	23	Tank Installed Date	04/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3969	Spill Test Date	12/14/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/14/2021			ATG Type					

Facility Summary in Richland County in the City of Sidney

Location: SIDNEY CARDTROL

901 3rd St NE

Sidney, MT 59270 Richland

Facility Code: 27135
Last Inspected On: 07/20/2022
System Facility ID:42-02184
Operating Permit Renewal Date: 10/24/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Report Created: 11/1/2022 Page [15] of [26]

Operator Contact: Gregory Cross;Larry Garman;R J Serpe;Timothy Fife

4064824376

Owner/Operator: Cross Petroleum Services Glendive

Greg Cross, UST Class A Operator
Larry Garman, UST Class A Operator
Larry Garman, UST Class B Global Operator
R J Serpe, UST Class A Operator
R J Serpe, UST Class B Global Operator
Timothy Fife, UST Class A Operator

Tank Code	01	Tank Age	40	Tank Installed Date	04/17/1982	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	776	Spill Test Date	10/07/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/20/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2021			ATG Type	Franklin Fueling Systems/TS- LLD;Incon/TS- 1001				
Tank Code	02	Tank Age	40	Tank Installed Date	04/17/1982	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	777	Spill Test Date	03/30/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/20/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2021			ATG Type	Franklin Fueling Systems/TS- LLD;Incon/TS- 1001				
Tank Code	03	Tank Age	40	Tank Installed Date	04/17/1982	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	778	Spill Test Date	10/07/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Report Created: 11/1/2022 Page [16] of [26]

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/20/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2021			ATG Type	Franklin Fueling Systems/TS- LLD;Incon/TS- 1001				
Tank Code	04	Tank Age	40	Tank Installed Date	04/17/1982	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	779	Spill Test Date	10/07/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	07/20/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/20/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/07/2021			ATG Type	Franklin Fueling Systems/TS- LLD;Incon/TS- 1001				

Location: SIDNEY HEALTH CENTER

216 14th Ave SW

Sidney, MT 59270-3519 Richland

Facility Code: 27255 Last Inspected On: 04/14/2021

System Facility ID:42-06159

Operating Permit Renewal Date: 09/14/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sidney Health Center Inc 4064822120

Operator Contact: Mark Delaney

Owner/Operator: Sidney Health Center Inc

Mark Delaney, UST Class A Operator Mark Delaney, UST Class B Operator Robert Jes, UST Class B Operator

Tank Code 02 Tank Installed 25 09/01/1997 **Tank Material** Steel Clad **Piping Material Overfill Types** Flapper Valve Tank Age Flexible Plastic Date

Page [17] of [26] Report Created: 11/1/2022

Tag Number	700	Spill Test Date	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	Sump Tightness Test Date	04/13/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	Tank/Piping CP Test Date	04/19/2012	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	Line Tightness Test Date	03/18/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date			ATG Type					

System Facility ID:42-09718

Location: SUPERPUMPER 23

902 S Central Ave

Sidney, MT 59270-5216 Richland

Facility Code: 27348

Last Inspected On: 10/04/2021 Operating Permit Renewal Date: 12/26/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Parkland USA Corporation 7018521194

Operator Contact: Kristopher Wolla; Shane Farstad; Steven Mack 5702020945; 7018520061

Owner/Operator: Parkland USA Corporation

Al Erickson, UST Class B Operator

Greg Schimetz, UST Class B Global Operator

Jessica Shaffer, UST Class B Operator

Kristopher Wolla, UST Class A Operator

Lory Polensky, UST Class B Operator

Roger Pelzer, UST Class B Operator

Shane Farstad, UST Class A Operator

Shane Farstad, UST Class B Global Operator

Steven Mack, UST Class A Operator

Steven Mack, UST Class B Operator

Susan Hurley, UST Class B Operator

Tank Code	06	Tank Age	7	Tank Installed Date	11/16/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5595	Spill Test Date	07/09/2019	Piping Installed Date	11/16/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/09/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Report Created: 11/1/2022 Page [18] of [26]

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/09/2019			ATG Type	Franklin Fueling Systems/TS- LS500 Series;Incon/TS- 550 EVO				
Tank Code	07	Tank Age	7	Tank Installed Date	11/16/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5596	Spill Test Date	07/09/2019	Piping Installed Date	11/16/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/09/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/09/2019			ATG Type	Franklin Fueling Systems/TS- LS500 Series;Incon/TS- 550 EVO				
Tank Code	08	Tank Age	7	Tank Installed Date	11/16/2015	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5597	Spill Test Date	07/09/2019	Piping Installed Date	11/16/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/09/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/09/2019			ATG Type	Franklin Fueling Systems/TS- LS500 Series;Incon/TS- 550 EVO				

Report Created: 11/1/2022 Page [19] of [26]

Location: SWELEY OIL INC BULK PLANT

1123 10th Ave SE

Sidney, MT 59270-6393 Richland

System Facility ID:42-00183

Facility Code: 27064
Last Inspected On: 10/26/2021
Operating Permit Renewal Date: 02/18/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Nortana Grain Co 4064432580

Operator Contact: John Sweley;Mike Arneson 4064822508;4064893589

Owner/Operator: Nortana Grain Co

John Sweley, UST Class A Operator John Sweley, UST Class B Operator Mike Arneson, UST Class A Operator Mike Arneson, UST Class B Operator

Tank Code	S4	Tank Age	24	Tank Installed Date	06/16/1998	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	2076	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/26/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	17000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S5	Tank Age	24	Tank Installed Date	06/16/1998	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	2077	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/26/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	17000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Report Created: 11/1/2022 Page [20] of [26]

Location: TOWN PUMP OF SIDNEY #3 12280 Hwy 200 Unit 1 Sidney, MT 59270 Richland

System Facility ID:60-15241

Facility Code: 30958
Last Inspected On: 09/11/2020
Operating Permit Renewal Date: 01/14/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sidney 3 Town Pump LLC 4064976700

Operator Contact: Trent Biggers

Owner/Operator: Sidney 3 Town Pump LLC

Brian Volbrecht, UST Class B Global Operator Trent Biggers, UST Class A Operator Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	8	Tank Installed Date	03/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5471	Spill Test Date		Piping Installed Date	03/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	08/09/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/10/2021			ATG Type	Gilbarco-Veeder Root/TLS- 350;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	8	Tank Installed Date	03/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5472	Spill Test Date	09/10/2021	Piping Installed Date	03/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Report Created: 11/1/2022 Page [21] of [26]

Capacity	30000	ATG Test Date	08/09/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/10/2021			ATG Type	Gilbarco-Veeder Root/TLS- 350;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	8	Tank Installed Date	03/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5473	Spill Test Date		Piping Installed Date	03/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	08/09/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS- 350;Veeder Root/8484 Series PLLD				
Tank Code	04	Tank Age	8	Tank Installed Date	03/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5474	Spill Test Date	09/10/2021	Piping Installed Date	03/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	08/09/2022	Line Tightness Test Date	03/13/2019	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS- 350;Veeder Root/8484 Series PLLD				
Tank Code	05	Tank Age	8	Tank Installed Date	03/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5475	Spill Test Date		Piping Installed Date	03/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Report Created: 11/1/2022 Page [22] of [26]

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	08/09/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS- 350;Veeder Root/8484 Series PLLD				
Tank Code	06	Tank Age	8	Tank Installed Date	03/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5476	Spill Test Date		Piping Installed Date	03/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/09/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS- 350;Veeder Root/8484 Series PLLD				
Tank Code	07	Tank Age	8	Tank Installed Date	03/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5477	Spill Test Date		Piping Installed Date	03/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/14/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/09/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS- 350;Veeder Root/8484 Series PLLD				

Report Created: 11/1/2022 Page [23] of [26]

Tank Code	08	Tank Age	8	Tank Installed Date	03/01/2014		Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5478	Spill Test Date		Piping Installed Date	03/24/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type					

Location: WESTERN CHOICE COOPERATIVE SIDNEY

1281 S Central Ave

Sidney, MT 59270-5221 Richland

System Facility ID:42-03364

Facility Code: 27176 Last Inspected On: 12/08/2021 Operating Permit Renewal Date: 02/11/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Western Choice Cooperative

7017646791

Operator Contact: Jade Ziman; Western Choice Cooperative; Serena

Ewer; Western Choice Cooperative

7015900693;7017646791;7017646791

Owner/Operator: Western Choice Cooperative

Jade Ziman, UST Class A Operator Jade Ziman, UST Class B Operator Serena Ewer, UST Class A Operator Serena Ewer, UST Class B Operator

Tank Code	05	Tank Age	41	Tank Installed Date	06/25/1981	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4046	Spill Test Date	06/15/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	11/23/2021	Tank/Piping CP Test Date	11/23/2021	Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	11/23/2021	Line Tightness Test Date	04/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/14/2022			ATG Type	Veeder Root/TLS- 450				

Page [24] of [26] Report Created: 11/1/2022

Tank Code	01	Tank Age	41	Tank Installed Date	06/25/1981	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	602	Spill Test Date	06/15/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Γank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	11/23/2021	Tank/Piping CP Test Date	11/23/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/23/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/14/2022			ATG Type	Veeder Root/TLS- 450				
ank Code	02	Tank Age	41	Tank Installed Date	06/25/1981	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Гад Number	603	Spill Test Date	06/15/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Γank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/23/2021	Tank/Piping CP Test Date	11/23/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/23/2021	Line Tightness Test Date	04/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/14/2022			ATG Type	Veeder Root/TLS- 450				
Tank Code	03	Tank Age	41	Tank Installed Date	06/25/1981	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Гад Number	604	Spill Test Date	12/15/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Γank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	11/23/2021	Tank/Piping CP Test Date	11/23/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/23/2021	Line Tightness Test Date	04/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/14/2022			ATG Type	Veeder Root/TLS- 450				
ank Code	04	Tank Age	41	Tank Installed Date	06/25/1981	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
rag Number	605	Spill Test Date	06/15/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
 Γank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Report Created: 11/1/2022 Page [25] of [26]

Product	Gasoline	PLLD Test Date	11/23/2021	Tank/Piping CP Test Date	11/23/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	11/23/2021	Line Tightness Test Date	04/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/14/2022			ATG Type	Veeder Root/TLS- 450				